

City of Commerce
Requirements
For Emergency Generators

Obtain Planning Department Approval

Submit Minimum (2) Sets of Plans to Planning Dept.

Plans must show:

1. **Site Plan** must show location of proposed generator and Protection of Generator from public and company personnel
2. Note must be placed on Plan explaining intended use, and the date to be removed
3. **Plan size** must be a minimum of 24"x36"
4. **Scale on Plan** must be placed on drawing (Minimum 1/8"=1', Preferred ¼"=1')

Note: Letter of **AQMD** Notification and/or **Generator Permit** is Required before Permit Issuance